

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 46

Dated: 18-02-2026

It is certified that an inspection team headed by Shri Karan Soan

(Name of Officers with designation) from Assistant Executive Engineer

(Name of Department/ Office) inspected the RWS&S Section, Champua

(Name & Address of the school) on 18-02-2026 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal:

Soan
18/02/26

Name :

Assistant Executive Engineer

Designation :

RWS&S Section Jhumpura

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

The Principal

Eklavya Model Residential School, Gadhikera, Keonjhar

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

SUB-DIVISION WATER TESTING LABORATORY RWS&S SUB-DIVISION, CHAMPUA

At/PO -Champua, Dist-Keonjhar
Odisha, Pin: 758041

Email: labrwschampua@gmail.com

DRINKING WATER ANALYSIS REPORT



Lab Ref. No. 115/2025-26

Dated 21.02.2026

To

The Principal
Eklavya Model Residential School, Gidhibas, Keonjhar
AT/PO Gidhibas, Sub-Division - Champua Dist Keonjhar Odisha, 758032
Type of source- Deep Borewell
Sample Receive Date -18.02.2026


Test Result					
Test started on-19.02.2026			Test completed on-21.02.2026		
Sl. No.	Name of the Parameters	Unit	Results obtained	Requirements IS:10500:2012	
				Acceptable Limit	Permissible Limit in absence of alternate source
1	Temperature	°C	25.3	-----	-----
2	pH		6.54	6.50-8.50	No relaxation
3	Turbidity	NTU	0.2	1.00	5.00
4	TDS	mg/l	194	500	2000
5	Chloride	mg/l	24	250	1000
6	T.Alkalinity as CaCO ₃	mg/l	164	200	600
7	T.Hardness as CaCO ₃	mg/l	124	200	600
8	Calcium (as Ca)	mg/l	22.44	75	200
9	Magnesium (as Mg)	mg/l	16.52	30	100
10	Fluoride	mg/l	0.89	1.0	1.5
11	Iron	mg/l	0.06	0.3	1.0
12	Elect. Conductivity	uScm	298.5	1000	1000
13	Total Coliform	MPN/100 ml	0	0	0
14	E. Coli	MPN/100 ml	0	0	0

Note: As per above parameters tested water is potable

Information on Test Report:

Results relates only to sample received in the Laboratory.

----- End of Report -----


 21/02/26
 Lab Chemist
 Sub-Divisional Water Testing Laboratory
 RWS&S Sub-Division, Champua